

120ACT GENERAL NOTES:

1. TOTAL ESTIMATED DESIGN WEIGHT: () LBS.
2. PANEL CONSTRUCTION: NOISELOCK V (INNER WALLS), NOISELOCK IV (OUTER WALLS & OUTER CEILINGS) AND NOISELOCK VI (INNER CEILINGS)

INTERIOR SURFACES: 22GA. GALVANIZED STUCCO EMBOSSED PERFORATED STEEL
EXTERIOR SURFACES: 14GA. COLD ROLLED STUCCO EMBOSSED SOLID STEEL
FLOOR INTERIOR SURFACE: 11GA. HOT ROLLED STEEL
3. FINISH: BAKED ACRYLIC ENAMEL PAINT
COLOR: CHOICE OF (10) STANDARDS
4. FLOOR COVERING: INDUSTRIAL NYLON CARPET
COLOR: (TO MATCH PAINT COLOR SELECTION)
3/8" THICK UNDERLAYMENT AND 2 1/2" H BLACK COVE BASE MOLDING INCLUDED.
5. DOOR: (3) 2' X 9" WIDE X 6' – 1 1/2" HIGH CLEAR OPENING CAM-LIFT SPLIT-FRAME WITH PUSH PLATE AND PULL HANDLES.
NOTE: A. DIMENSIONS LOCATING DOOR ARE SHOWN TO THE CLEAR OPENING
B. FOR CONTROL SIDE, SINGLE OUTSWINGING STC 64 DOOR STANDARD. ALTERNATE FOR LARGER SUITES IS A COMBINATION OF ONE OUTSWINGING AND ONE INSWINGING STC 51 DOORS.
6. WINDOW: (2) 2'6" WIDE X 2'10" HIGH ALUMINUM FRAME DOUBLE GLAZED WITH 1/4" THICK LAMINATED SAFETY GLASS (WIDTH REDUCED ON SMALLER MODELS).
7. VIBRATION ISOLATOR RAILS TO BE PROVIDED BELOW FLOOR PANELS.
8. 2" MINIMUM CLEARANCE IS REQUIRED BETWEEN THE EXTERIOR OF TESTING SUITE AND HOST FACILITY WALLS/CEILING.
9. DUST SEAL TO BE PROVIDED WITHIN AIRSPACE AROUND DOORS AND WINDOWS. SILL ANGLE TO BE PROVIDED BETWEEN DOORS.
10. LARGEST PANEL SIZE: () WIDE X () LONG X () THICK. CUSTOMER TO ENSURE ADEQUATE SITE ACCESS.

INDUSTRIAL ACOUSTICS COMPANY, INC.

Rev. 1 May 2006

11. VENTILATION: () CFM SYSTEM (EXAM) AND () CFM SYSTEM (CONTROL) COMPRISED OF INTEGRATED SPASAVER EXHAUST/INLET AIR CEILING SILENCER PANELS AND 120V, 60HZ, 14W FANS.
12. ELECTRICAL:
- () 120V RECESSED INCANDESCENT LIGHT FIXTURE
 - (4) 120V TOGGLE SWITCH FOR FANS AND LIGHTS
 - () 120V DUPLEX RECEPTACLE
 - (2) 120V QUAD RECEPTACLE WITH POWER CORD (ROOF MOUNTED)
 - () 120V J-BOX WITH POWER CORD (ROOF MOUNTED)
 - (1) JP-81 AUDIOMETRIC JACK PANEL COMPRISED OF:
 - (10) SWITCHCRAFT #12B JACKS (INSIDE AND OUTSIDE)
 - (1) CINCH-JONES #S303-RP (INSIDE)/(1) CINCH JONES #P-303-RP (OUTSIDE)
 - (1) CINCH-JONES #S304-RP (INSIDE)/(1) CINCH JONES #P-304-RP (OUTSIDE)
 - (2) 1" I.D. GROMMETED OPENINGS (INSIDE AND OUTSIDE)
 - (LOT) BOXES, CONNECTORS, ETC. AS REQUIRED FOR COMPLETE INSTALLATION

NOTE:

- A. CUSTOMER TO PROVIDE 110V, 60 HZ, 20 AMP POWER TO ROOF MOUNTED QUAD RECEPTACLE POWER CORD.
- B. ALL ELECTRICAL IS WIRED PER 2002 NATIONAL ELECTRIC CODE
- C. BOOTH IS FACTORY UL CERTIFIED AND LABELED

13. CUSTOMER TO PROVIDE A FINISHED FLOOR WHICH IS WITHIN +/- 1/4" OF LEVEL IN 10 NON-CUMULATIVE FEET.