

30A VALUE GENERAL NOTES:

1. TOTAL ESTIMATED DESIGN WEIGHT: () LBS.
2. PANEL CONSTRUCTION: NOISHIELD CONOMY (WALLS) AND NOISELOCK VI (CEILING)

INTERIOR SURFACES: 22GA. NCT GALVANIZED PERFORATED STEEL
EXTERIOR SURFACES: 14GA. COLD ROLLED STUCCO EMBOSSED
SOLID STEEL FLOOR INTERIOR SURFACE: 11GA. HOT ROLLED STEEL
3. FINISH: BAKED ACRYLIC ENAMEL PAINT
COLOR: CHOICE OF (10) STANDARDS
4. FLOOR COVERING: INDUSTRIAL NYLON CARPET
COLOR: (TO MATCH PAINT COLOR SELECTION)
3/8" THICK UNDERLAYMENT AND 2 1/2" H BLACK COVE BASE MOLDING INCLUDED.
5. DOOR: (1) 2' X 9" WIDE X 6' – 1 1/2" HIGH CLEAR OPENING CAM-LIFT SPLIT-FRAME WITH PUSH PLATE AND PULL HANDLES. NOTE: DIMENSIONS LOCATING DOOR ARE SHOWN TO THE CLEAR OPENING
6. WINDOW: (1) 2'6" WIDE X 2'10" HIGH ALUMINUM FRAME DOUBLE GLAZED WITH 1/4" THICK LAMINATED SAFETY GLASS (WIDTH REDUCED ON SMALLER MODELS).
7. VIBRATION ISOLATOR RAILS TO BE PROVIDED BELOW FLOOR PANELS.
8. 2" MINIMUM CLEARANCE IS REQUIRED BETWEEN THE EXTERIOR OF TESTING BOOTH AND HOST FACILITY WALLS/CEILING.
9. LARGEST PANEL SIZE: () WIDE X () LONG X () THICK. CUSTOMER TO ENSURE ADEQUATE SITE ACCESS.
10. VENTILATION: () CFM SYSTEM COMPRISED OF INTEGRATED SPASAVER EXHAUST/INLET AIR CEILING SILENCER PANELS AND 120V, 60HZ, 14W FANS.
11. ELECTRICAL:
 - () 120V RECESSED INCANDESCENT LIGHT FIXTURE
 - (2) 120V TOGGLE SWITCH FOR FANS AND LIGHTS
 - () 120V DUPLEX RECEPTACLE
 - (1) 120V QUAD RECEPTACLE WITH POWER CORD (ROOF MOUNTED)

INDUSTRIAL ACOUSTICS COMPANY, INC.

Rev. 1 May 2006

- () 120V J-BOX WITH POWER CORD (ROOF MOUNTED)
- (1) JP-81 AUDIOMETRIC JACK PANEL COMPRISED OF:
- (10) SWITHCRAFT #12B JACKS (INSIDE AND OUTSIDE)
- (1) CINCH-JONES #S303-RP (INSIDE)/(1) CINCH JONES #P-303-RP (OUTSIDE)
- (1) CINCH-JONES #S304-RP (INSIDE)/(1) CINCH JONES #P-304-RP (OUTSIDE)
- (2) 1" I.D. GROMMETED OPENINGS (INSIDE AND OUTSIDE)
- (LOT) BOXES, CONNECTORS, ETC. AS REQUIRED FOR COMPLETE INSTALLATION

NOTE:

- A. CUSTOMER TO PROVIDE 110V, 60HZ, 20 AMP POWER TO ROOF MOUNTED QUAD RECEPTACLE POWER CORD
- B. ALL ELECTRICAL IS WIRED PER 2002 NATIONAL ELECTRIC CODE
- C. BOOTH IS FACTORY UL CERTIFIED AND LABELED

- 12. CUSTOMER TO PROVIDE A FINISHED FLOOR WHICH IS WITHIN +/- 1/4" OF LEVEL IN 10 NON-CUMULATIVE FEET.